



## *The Quality Chicken People*

### **ALLEN HARIM FOODS, LLC**

Harbeson Plant  
P.O. Box 63  
18752 Harbeson Rd.  
Harbeson, DE 19951  
TEL (302) 684 - 1640 • FAX (302) 684 - 0584



August 6, 2012

Mr. Glenn Davis, Program Manager  
State of Delaware – DNREC  
Division of Water Resources  
Surface Water Discharges Section  
89 Kings Highway  
Dover, Delaware 19901

Re: Permit #DE0000299  
Discharge Outfall SW 003

Dear Mr. Davis:

This letter is to follow up to the August 2, 2012 verbal notification to Ms. Beth Krumrine in which the analytical results of the July 20, 2012 discharge from Storm Water Outfall 003 (SW 003) were reported. Per the notification requirements of Part II, Section A.2.b.1 of the referenced permit Allen Harim Foods, LLC, is reporting the following:

#### Allen's – Harbeson 003 Grab Sample


Sample Date	Parameter	Results
July 20, 2012	BOD	31.2 mg/L
July 20, 2012	TSS	474.0 mg/L

At approximately 0300 hours it was noticed that a discharge was occurring at SW 003. In accordance with the reference permit requirements a grab sample was taken. The discharge lasted approximately 30 minutes with an estimated 22,000 gallons discharged.

It was determined that the reason for the discharge was that the pump at 003 stopped working. The plant electrician was called to the station to determine why the pump was not operating. It was determined that one of three overloads (heaters) in the panel box had failed. All three overloads were immediately replaced with new overloads on July 20, 2012.

If you should have any questions, please contact me at (302) 684-1640, Ext. 184.

Respectfully submitted,  
ALLEN HARIM FOODS, LLC.

A handwritten signature in cursive script that reads "Michael R. Sausé". The signature is written in black ink and is positioned above the printed name and title.

Michael R. Sausé  
Wastewater Manager

*"Preparing Food for our Families"*